

Boiler Tune-Up Services Checklist



Customer:

Manufacturer:

Model #:

Boiler Type:

Boiler Size (MBH):

Please check each completed task below:

- Measure pre/post combustion efficiency using electronic flue natural gas analyzer
- Include a copy of the combustion analyzer test
- Adjust air flow and reduce excessive stack temperatures
- Adjust burner and natural gas input, manual or motorized draft control
- Clean burners, combustion chamber and heat exchanger surfaces
- Clean and inspect burner nozzles
- Complete visual inspection of system piping and installation
- Check safety controls

	Before	After
Combustion Efficiency		
Stack Temperature		
Oxygen Level		
Carbon Dioxide		
Carbon Monoxide		

Additional Comments:

Service Technician:

Service Date:



Online
Application



PDF
Application